

| Sl. No. | Particulars                                                                                                                                                                                                                                                                                                                 | Quantity |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|
| 2       | Supplying, fixing and wiring a varnished T.W. Board 12"×9"×1" with batten and rear board, equipping it with a D.P. linked switch 5-amp. two 5-amp. bow cutouts using No. 14 B. & S. insulated wire, 2,500 Meg. grade and accessories                                                                                        | 1        |
| 3       | Do do in 2"×1" two way T.W. casing treated with 2 coats of shellac varnish for $\frac{5}{8}$ " braized conduit pendant 2-ft. long complete with ceiling plate B.C. lampholder, 5-amp. tumbler switch, $\frac{5}{8}$ " braized conduit for the open space and No. 14 B. & S. insulated wire 2,500 Meg. grade and accessories | 2        |
| 4       | Supplying and fixing shade tin enamelled                                                                                                                                                                                                                                                                                    | 2        |
| 5       | Do lamps 220-v, 30 to 40-w, B.C.                                                                                                                                                                                                                                                                                            | 2        |
| 6       | Grounding                                                                                                                                                                                                                                                                                                                   | Item.    |

"F".

Installing electric lights to the Nurses' quarters attached to Chamarajendra Hospital at Hassan :—

| Sl. No. | Particulars                                                                                                                                                                                                                                                | Quantity |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|
| 1       | Supplying and running mains in $\frac{1}{2}$ " W.I. pipe with necessary accessories, 3 sets of clamps, using No. 14 B. & S. insulated wire, 2,500 Meg. grade                                                                                               | 26 R.ft. |
| 2       | Supplying and fixing and wiring a varnished T.W. board 12"×9"×1" with batten and rear board, equipping the same with a D.P. linked switch 5-amp. two 5-amp. bow cutouts using No. 14 B. & S. insulated wire 2,500 Meg. grade and accessories               | 1        |
| 3       | Do do in 2"×1" two way T.W. casing treated with 2 coats of shellac varnish for $\frac{5}{8}$ " braized conduit pendant 2-ft. long complete with ceiling plate, B.C. lampholder, 5-amp. tumbler switch using No. 14 B. & S. insulated wire 2,500 Meg. grade | 1        |
| 4       | Do do for drop lights complete with ceiling rose, flexible cord, B.C. holder, 5-amp. tumbler switch and accessories using No. 14 B. & S. insulated wire, 2,500 Meg. grade                                                                                  | 2        |
| 5       | Supplying and fixing shade tin enamelled                                                                                                                                                                                                                   | 1        |
| 6       | Do do shade langham                                                                                                                                                                                                                                        | 2        |
| 7       | Do do lamps B.C., 30-w., 220-v.                                                                                                                                                                                                                            | 3        |
| 8       | Grounding                                                                                                                                                                                                                                                  | Item     |

A. C. MUNIRATNA MUDALIAR,  
Superintendent.

## MYSORE RAILWAYS.

OFFICE OF THE TRAFFIC MANAGER, MYSORE.

Abstract Notification dated 25th November 1936.

Re AUCTION SALE OF L. P. O. ARTICLES TO BE HELD AT MYSORE ON 13TH DECEMBER 1936.

The attention of the public is invited to the detailed notification published in the *Mysore Gazette*, dated 26th November 1936, regarding the Auction Sale of the Lost Property Office articles to be held at Mysore Railway Station on Sunday the 13th December 1936.

H. D. SINCLAIR,  
Traffic Manager.

MYSORE DIVISION (OPEN LINES).

Abstract Notification dated 27th November 1936.

The attention of the public is invited to the detailed Notification, dated 17th November 1936, published in the *Mysore Gazette*, dated 26th November 1936, on pages 1929 and 1930 of Part VI, regarding supplying and fixing Reinforced Concrete Fencing at Mandya Railway Station.

The last date of receiving tenders is up to 3 P.M. on Monday the 7th December 1936.

D. V. NARASIMHA RAO,  
Ag. Executive Engineer.